

**RELAY RACK—ANGLE TYPE
FRAMEWORK AND CABLING
EQUIPMENT DESIGN REQUIREMENTS
COMMON SYSTEMS**

1. GENERAL

1.001 This addendum supplements Section 801-006-155, Issue 4.

1.002 This addendum is issued to show the addition of a new frame width, namely 3 feet 0-1/4 inch.

The following changes apply to Part 1 of the section:

Change: 1.05

To Read:

1.05 Width: The relay racks are furnished in bays of two basic widths, namely 2 feet 0-5/8 inch and 3 feet 0-1/4 inch measured across....

Bell Telephone Laboratories, Incorporated

Dept 5224

2. SUPPLEMENTARY INFORMATION

The following change applies to Part 2 of the section:

Change: Table A Reference

To Read:

Relay racks 11 feet 6 inches high, 1 foot 8-5/8 inches wide for 1-3/4 and 2-inch mounting plates; relay racks 9 feet 0 inch high, 2 feet 0-5/8 inch for 1-3/4 inch mounting plates; and relay racks 7 feet 0 inch high, 2 feet 0-5/8 inch wide for 2-inch mounting plates are also available.